

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. **82556**  
 Permit No. **104**  
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **42903**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER **Sierra West Inc.** ADDRESS AT WELL LOCATION **4950 Oak St. Carson City, NV.**  
 MAILING ADDRESS **P.O. Box 8346 Incline Village, NV 89452**

2. LOCATION **1/4 NW 1/4 Sec. 32 T 15N N/S R 20E E Carson City** County  
 PERMIT NO. **9-191-05** Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other  Municipal/Industrial

4. PROPOSED USE  
 Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 84' of 1 inch pipe and 1.5hp pump from well. Measured static water level at 60.4' and the depth of the well at 96'. Bailed debris from well to a depth of 99'. We installed 8 inch Mills Knife and perforated well from 66' to 35' with 5 rows per foot. We then removed perforator and installed 94' of tremme pipe. We mixed 42 bags of cement with 220 gallons and pumped well full of cement.				
On the same property, approximately 100' due south, there was a 6" casing approximately 33' deep. This hole was dry so we installed a pipe to 30' and blew dirt from the well until we hit a hard bottom at 41'. We then mixed 12 bags of cement and 60 gallons of water and pumped the well full of cement. There was no drillers log on this well.				

*Plugging of log # 13574*

8. WELL CONSTRUCTION

Depth Drilled **100** Feet Depth Cased **95** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	0	95

Perforations:

Type perforation **Mills Knife**

Size perforation

From	To	feet to	feet
66	35		

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level **60.2** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Carson Pump** Contractor

Address **P.O. Box 20159** Contractor  
**Carson City, NV, 89721**  
 Nevada contractor's license number issued by the State Contractor's Board **39920**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1482**

Signed *San J. [Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **3/1/01**

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift  
 Draw Down (Feet Below Static) Time (Hours)

G.P.M. \_\_\_\_\_

RECEIVED  
 DIVISION OF WATER RESOURCES  
 STATE ENGINEERING OFFICE  
 APR 5 11:23 AM '01