

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33440  
119 Upper Colony Rd  
Wellington Nev 89444

1. OWNER Dewey Fleck ADDRESS AT WELL LOCATION  
MAILING ADDRESS Box 110  
Wellington, Nev 89444

2. LOCATION SE 1/4 SW 1/4 Sec 27 T. 4 N/S R. 23 F. Lyon County  
PERMIT NO. 10-351-47 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvial Small Rock &amp; D.G. dirt</u>		<u>0</u>	<u>130</u>	<u>130</u>
<u>Sharp Gravel</u>		<u>130</u>	<u>155</u>	<u>25</u>
<u>Coarse Sand + gravel</u>	<u>yes</u>	<u>155</u>	<u>172</u>	<u>17</u>
<u>Hard yellow clay</u>		<u>172</u>	<u>185</u>	<u>13</u>
<u>Sharp gravel + sand</u>		<u>185</u>	<u>205</u>	<u>20</u>

8. WELL CONSTRUCTION  
Depth Drilled 205 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches 0 Feet 50 Feet  
To 6 Inches 50 Feet 205 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>1 3/8</u>	<u>0</u>	<u>200</u>

Perforations:  
Type perforation Factory saw slot  
Size perforation 5 3/8  
From 150 feet to 200 feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50 ft.  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From..... feet to..... feet

Date started JAN 18 2001  
Date completed Feb 21 2001

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>25</u>	<u>8 ft.</u>	<u>3</u>

9. WATER LEVEL  
Static water level 140 feet below land surface  
Artesian flow..... G.P.M. P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Edmund Miller Drilling Contractor  
Address P.O. Box 92 Contractor  
Smith, Nev 89430  
Nevada contractor's license number 32166  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the 718  
Division of Water Resources, the on-site driller.  
Signed Edmund Miller  
By driller performing actual drilling on site or contractor  
Date 2-28-01