

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 82564  
 Permit No. 105  
 Basin 105  
 NOTICE OF INTENT NO. **45843**  
 ADDRESS AT WELL LOCATION **1565 LINDSEY MINDEN, NV 89423**

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **RICHARD MORISSETTE**  
 MAILING ADDRESS **LAS VEGAS NV**  
 ADDRESS AT WELL LOCATION **1565 LINDSEY MINDEN, NV 89423**

2. LOCATION **NW 1/4 SW 1/4 Sec 27 T 14 N R 20 E DOUGLAS County**

PERMIT NO. **1420-27-701-0024**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOFT SANDS		0	3	3
HARDPAN CLAY		3	6	3
DG SANDS AND SOFT BLOW SANDS		6	21	15
COURSE DG SANDS VERY SANDY		21	175	154
BROWN SILTY CLAY		175	237	62
DG SANDS		237	248	11
BROWN GUMMY CLAY		248	279	31
DG SANDS AND OBSIDIAN GRAVELS VERY SOFT ZONE	<b>XX</b>	279	310	31

8. WELL CONSTRUCTION

Depth Drilled **310** Feet Depth Cased **310** Feet

HOLE DIAMETER (BIT SIZE)

From	To
<b>10 5/8</b> Inches	<b>0</b> Feet <b>310</b> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13.03</b>	<b>.188</b>	<b>0</b>	<b>310</b>

Perforations:

Type perforation **MILL SLOT**  
 Size perforation **3 X 3/32**

From **290** feet to **310** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **55'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **55** feet to **310** feet

9. WATER LEVEL

Static water level **150** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **25+** P.S.I.  
 Water temperature **COLD** °F Quality **GOOF**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **CAPITAL CITY WELL DRILLING**  
 (CONTRACTOR)

Date started **2/12, 20 01**  
 Date completed **2/16, 20 01**

7. WELL TEST DATE

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>25+</b>	<b>45</b>	<b>3 HRS</b>

Address **20 KIT KAT DRIVE**  
 (CONTRACTOR)  
**CARSON CITY, NV 89706**  
 Nevada contractor's license number issued by the State Contractor's Board **41775**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**

Signed *Michael Z Jack*  
 By driller performing actual drilling on site or contractor  
 Date **2/15/01**