WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82584
Permit No. 67153
Basin 212

NOTICE OF INTENT NO. 21786

1. OWNER Wayne Newton
MAILING ADDRESS Same

ADDRESS AT WELL LOCATION 3300 E./Sunset Rd. LV Nev.

2. LOCATION NE ¼ NE ¼ Sec. 1 T. 22S N/S R. 61 E Clark County
PERMIT NO. 67153 (Issued by Water Resources) 177-01-502-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	18	
Clay		18	26	
Sand & Water		26	35	
Gravel & Water		35	40	
Clay		40	48	
Gravel		48	60	
Clay		60	100	
Gravel & Water	xx	100	130	
Sandstone & Gravel		130	145	
Gravel & Water	xx	145	180	
Let Cement Cure for 10 days				
around pipe 14". Weld up				
well & Make adapter for pump.				
No water leaking				
28" Hole -				

Date started 3/7/01, 19
Date completed 4/8/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
28 Inches	0 Feet	100 Feet
12 1/4 Inches	100 Feet	180 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14 1/2	36.54	.250	+2	100
9"	SCH 80	PVC	+1	180

Perforations:
Type perforation Saw
Size perforation 3/16 by 5 row
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 500 G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Address 5360 N. Bonita Vista (Contractor)
LV NEV 89149 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 5-7-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627