

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **82596**  
 Permit No. **162**  
 Basin **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20800

1. OWNER **Ron Murphy**  
 MAILING ADDRESS **240 E. Jodi Pahrump, NV 89048**

ADDRESS AT WELL LOCATION  
**240 E. Jodi**

2. LOCATION **NW 1/4 NW 1/4 Sec. 10 T 20S**  
 PERMIT NO. **35-111-27**  
 Issued by Water Resources Parcel No.

**N/S R 53E E Nye** County  
 Nye Subdivision Name

3. WORK PERFORMED  
 New Well Replace Recondition  
 Deepen Abandon Other

4. PROPOSED USE  
 Domestic  
 Municipal/Industrial  
 Irrigation  Test  
 Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown sandy loam		0	16	16
See next line	x	16	131	115
brown loam with caleche strings				
brown caleche	x	131	146	15
brown loam caleche strings	x	146	160	14

8. WELL CONSTRUCTION

Depth Drilled **160** Feet Depth Cased **160+1** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
**11** Inches **0** Feet **160** Feet  
 Inches Feet Feet Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>160</b>

Perforations:

Type perforation **sawcut**  
 Size perforation **.188**  
 From **140** feet to **160** feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **160** feet

9. WATER LEVEL

Static water level **60** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Rory Strickland*  
 By driller performing actual drilling on-site or contractor

Date **4.6.01**



Date started **3/27/01** 19\_\_  
 Date completed **3/27/01** 19\_\_

7. WELL TEST DATA  
 TEST METHOD: Bailer Pump Air Lift  
 G.P.M. Draw Down (Feet Below Static) Time (Hours)