WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82600
Permit No.
Basin 107

NOTICE OF INTENT NO. 44907

1. OWNER John & Beverly Walter
MAILING ADDRESS 1625 Orchard rd.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION #10 Dee ct. Smithvalley
89430

2. LOCATION NW 1/4 SE 1/4 Sec. 27 T 11N N/S R 24E E Lyon County
PERMIT NO. Issued by Water Resources
010-581-14 Parcel No.
Smithvalley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & cobbles	no	0	12	12
sand and pebbles	no	12	116	104
sandy clay	no	116	156	40
clay	no	156	176	20
Unsorted gravel and	no	176		
sand			193	17
dark gray clay	no	193	199	6
unsorted gravel and	yes	199		
boulders			234	35
brown clay	no	234	235	1

Date started 11/2/2000, 19__
Date completed 11/10/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
air lift	30		1hr

8. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	60	Feet
97/8	Inches	60	Feet	235	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
65/8	13	.188	+2	235

Perforations:
Type perforation Factory milled
Size perforation 1/8x3
From 215 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 235 feet

9. WATER LEVEL
Static water level 143 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc Contractor
Address 7780 Curry rd Contractor
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/10/2000

USE ADDITIONAL SHEETS IF NECESSARY