

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jeri Butler ADDRESS AT WELL LOCATION 179 Adair Rd
 MAILING ADDRESS Wilmington N.V.
 2. LOCATION S 1/2 1/4 SW 1/4 Sec. 28 T. 12 N/S R. 23 E Lyon County
 PERMIT NO. 10 Issued by Water Resources Parcel No. 09-021-18 Subdivision Name Wilmington Smith Valley

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>1</u>	<u>2</u>	
<u>Concrete Clay</u>		<u>2</u>	<u>11</u>	
<u>DB. Concrete</u>	<u>120</u>	<u>11</u>	<u>252</u>	
<u>Bedrock</u>	<u>260</u>	<u>232</u>	<u>260</u>	
<u>DC Decomposed Granite</u>				
<u>Some Clay Seams</u>				

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 1 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17</u>	<u>1.868</u>	<u>1</u>	<u>260</u>

 Perforations:
 Type perforation Machine Packed
 Size perforation 3/16 x 4 x 8 rows per
 From 180 feet to 260 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 260 feet
 9. WATER LEVEL
 Static water level 9.8' feet below land surface
 Artesian flow No G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

Date started 12/18/00, 19____
 Date completed 12/28/00, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>95+</u>		<u>3hr00</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Teach Drilling Inc Contractor
 Address PO 553 Contractor
S.G. NV 89425
 Nevada contractor's license number issued by the State Contractor's Board 003841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1826
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1/26/01

RECEIVED
 01 JAN 30 AM 10 51
 STATE ENGINEERS OFFICE