

OFFICE USE ONLY
 Log No. 82607
 Permit No. 87
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45037

1. OWNER EDWARD & CAROLYN SNYDER ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 5031 Pleasant View Drive
Sparks, Nevada 89434
 2. LOCATION NE 1/4 NW 1/4 Sec 1 T 19N N/S R 20 E Washoe County
 PERMIT NO. 030-204-05 Sunset View Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING				
Bottom of casing at 295 feet/clean bottom				
Broken multi-colored volcanic rock	X	295	318	23
Broken volcanic rock		318	333	15
Reddish brown fracture volcanic rock with some clay streaks	X	333	345	12
Broken volcanic rock		345	351	6
Broken fracture, black volcanic rock	X	351	374	23
Black volcanic rock		374	378	4

8. WELL CONSTRUCTION
 Depth Drilled 378 Feet Depth Cased 378 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 295 Feet 378 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	378

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 314 feet to 374 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 295 feet to 378 feet

9. WATER LEVEL
 Static water level 295 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature cold °F Quality clear

Date started October 9, 2000, 19____
 Date completed October 11, 2000, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 16, 2000