

OFFICE USE ONLY
 Log No. 82608
 Permit No. 179
 Basin I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40016

1. OWNER Gordon V. Foppiano
 MAILING ADDRESS P.O. Box 150691
Ely, Nevada 89315
 ADDRESS AT WELL LOCATION 1 1/2 miles east of
Cherry Creek, Nevada

2. LOCATION NW 1/4 NE 1/4 Sec 33 T 24 N 63 R 63 E White Pine County
 PERMIT NO. APN 8-180-06 Issued by Water Resources
 Parcel No. 40016 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Sand, gravel, small boulders		3	7	4
Clay & gravel		7	30	23
Water bearing gravel	X	30	50	20
Brown clay		50	80	30
Clay & coarse gravel		80	90	10
Brown clay		90	100	10
Gravel w/ clay stringers		100	110	10
Brown clay		110	130	20
Clay & gravel	X	130	140	10
Brown clay		140	162	22

8. WELL CONSTRUCTION
 Depth Drilled 162 Feet Depth Cased 162 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 162 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	162

Perforations: Factory
 Type perforation 1/8" x 2 1/2"
 Size perforation 6 Rows
 From 101 feet to 162 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 162 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started September 12 2000
 Date completed September 20 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>45</u>	<u>119</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793
 Division of Water Resources, the on-site driller:
 Signed Rich Lewis By Jonell D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 12, 2000

RECEIVED
 OCT 16 PM 12:12
 STATE ENGINEER'S OFFICE