WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82473
Permit No.
Basin 92B

NOTICE OF INTENT NO. 46618

1. OWNER Greater Sierra Development
MAILING ADDRESS 455 Arkansas
Reno, Nevada, NV 89506

ADDRESS AT WELL LOCATION 3435 Warpaint
Reno, Nevada 89506

2. LOCATION NW 1/4 SE 1/4 Sec. 11 T 20N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 552-073-14 | Subdivision Name Golden Valley

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
D.G.		0	130	130
White Rock & Quartz	x	130	173	43
T.D. 173		173		

Date started 01/22/2001, 19__
Date completed 01/23/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	125	1 hour
20	150	1 hour
30	173	1 hour

8. **WELL CONSTRUCTION**
Depth Drilled 173 Feet Depth Cased 173 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	50	Feet
8-3/4	Inches	50	Feet	173	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	+2	173

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3
From 153 feet to 173 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 173 feet

9. **WATER LEVEL**
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature cool °F Quality good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nevada
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed (By driller performing actual drilling on-site or contractor)
Date 01/26/2001

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED JAN 30 2001 DIVISION OF WATER RESOURCES