STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 82630
Permit No.
Basin 91
NOTICE OF INTENT NO 44855

1. OWNER Somersett LLC
MAILING ADDRESS 100 West Liberty Suite 820
Reno NV 89501
ADDRESS AT WELL LOCATION

2. Location SE 1/4 SW 1/4 Sec 2 T 19N R 18E Washoe County
PERMIT NO. 66535 W-526 PARCEL N0. 38-360-33 SUBDIVISION NAME

3. WORK PERFORMED
X New Well | Replace | Recondition
Deepen | X Abandon | Other

4. PROPOSED USE
Domestic | Irrigation | X Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
Air | Other | X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan brown yellow clay.		0	12	12
Green clay with green red brown sand.		12	120	0 108
Green white yellow semi decomposed granite with light green clay strings.		120	170	0 0 50
Gray clay with blue white green sands.		170	210	0 40
Gray sticky clay with green sands & gravel lenses.		210	241	0 31
Sticky gray clay with traces of green sands.		241	370	0 129
Green vol rock fractured with gray clay lenses.		370	402	0 32
Sticky gray clay.		402	412	10
Light green clay stone with dark green vol rock.		412	458	0 46
Green sticky clay.		458	515	57
Green vol rock with green clay lenses.		515	715	0 200
Broken fractured green vol rock.		715	825	0 110
Install tremie & pumped cement grout. We did get returns.				0 0 0 0 0 0 0 0

Date started 9-14 -2000
Date completed 10-17 -2000

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)

8. WELL CONSTRUCTION
Depth Drilled 825 feet Depth Cased 0 feet
HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4	inches	0 feet	825 feet
	inches	feet	feet
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet

Perforations::
Type Perforation Factory
Size perforation 3/32 x 3"
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
see back
Surface Seal YES No
Depth of Seal feet
Pumped
Poured
Gravel Packed: Yes No
From feet to feet

Seal Type:
Neat Cement
Cement Grout
Concrete Grout

9 WATER LEVEL
Static water level feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cold Degrees F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. 14170
NV Driller's Lic (on site) 1511
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 11-8 -2000