WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82635
Permit No.
Basin 103

NOTICE OF INTENT NO. 42897

1. OWNER Stagecoach General Improv. Dist.
MAILING ADDRESS 5000 Navajo Trail
Stagecoach, NV 8929

ADDRESS AT WELL LOCATION 2 blocks east of Apache Drive on Navajo Trail, Well #2

2. LOCATION NE 1/4 NW 1/4 Sec. 2 T 17N N/S R 23 E Lyon County
PERMIT NO. 25639 (Issued by Water Resources) n/a (Parcel No.) n/a (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 115'. Measured depth of well to 307'. Removed 273' of 3" drop pipe with 20 hp pump. Installed Mills Knife to 194' and perforated 5 rows per foot from 194' to 65'. Installed 294' of 2" tremme pipe and pumped in 10 cubic yards of neat cement. Well volume should have only required 6.2 yards. Casing was then cut off 3" below ground surface.				
Original well log attached.				

RECEIVED
01 FEB 23 AM 11:34
STATE ENGINEER'S OFFICE

Date started 02/14/2001, 19__
Date completed 02/20/2001, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.188	0	307

Perforations:
Type perforation Mills Knife
Size perforation
From 65 feet to 196 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 307 to 0
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, Nv. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 02/21/2001

USE ADDITIONAL SHEETS IF NECESSARY