WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82634
Permit No.
Basin 103

NOTICE OF INTENT NO. 42895

OWNER Stagecoach General Improv. Dist.
MAILING ADDRESS 5000 Navajo Trail
Stagecoach, NV 89429

ADDRESS AT WELL LOCATION Approximately 1/2 mile west of Apache Drive on Iriquois Drive

2. LOCATION NW 1/4 NE 1/4 Sec. 3 T 17N N/S R 23 E Lyon County
PERMIT NO. n/a (Issued by Water Resources) n/a (Parcel No.) n/a (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The well log that we received from Stagecoach GID was incorrect. We measured the static water level at 140' and the depth of the well at 240'. The original property owner arrived on site and explained that the well was drilled to 250' and that it was perforated from 230' to 250'. We bailed the debris from the well until we hit hard bottom at 250'. We then installed our 8" perforator and perforated 5 rows per foot from 230' to 90'. The following day we pumped in 6 yards of neat cement. The actual well volume should have only required 3.2 cubic yards. The casing was then cut off 3' below grade.				

RECEIVED 01 FEB 23 AM 11:34 STATE ENGINEER'S OFFICE

Date started 02/14/2001, 19__
Date completed 02/15/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188		

Perforations:
Type perforation Mills Knife
Size perforation
From 90' feet to 230' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 250'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, Nv. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 02/21/2001

USE ADDITIONAL SHEETS IF NECESSARY