WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82637
Permit No.
Basin 103

NOTICE OF INTENT NO. 42894

1. OWNER Stagecoach General Improv. Dist.
MAILING ADDRESS 5000 Navajo Trail
Stagecoach, NV 89429

ADDRESS AT WELL LOCATION Approximately 5 blocks east of Apache Drive on Iriquois Drive in Stagecoach, Nv. Well #4

2. LOCATION NE 1/4 NW 1/4 Sec. 2 T 17N N/S R 23 E Lyon County
PERMIT NO. 26554 (Issued by Water Resources) | n/a (Parcel No.) | n/a (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 210' of 1 1/2" drop pipe with 5 hp pump. Measured static water level at 171'. Measured depth of well at 258'. Bailed debris fom well until we hit hard bottom at 265'. Installed Mills Knife in well, but could not advance past 20'. Installed 12" wire brush and brushed well for 1 hour to remove scale. Removed brush and installed Mills Knife to 260'. Perforated well from 260' to 120' with 5 rows per foot. We then set 260' of 2" tremme pipe and pumped in 11.5 cubic yards of neat cement. Actual well volume should have required 7.7 cubic yards.				
Original well log attached.				

RECEIVED 01 FEB 23 AM 11:34 STATE ENGINEER'S OFFICE

Date started 02/15/2001, 19__
Date completed 02/19/2001, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 268 Feet Depth Cased 268 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.188	+2	268

Perforations:
Type perforation Mills Knife
Size perforation
From 120 feet to 263 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 265'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 171 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, Nv. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 02/21/2001

USE ADDITIONAL SHEETS IF NECESSARY