


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **82638**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **20789**

1. OWNER **Van Vliet**  
 MAILING ADDRESS **581 S. Piltz**  
**Pahrump, NV 89048**

ADDRESS AT WELL LOCATION  
**581 S. Piltz**

2. LOCATION **NW 1/4 NE 1/4 Sec. 9 T 20S**  
 PERMIT NO. **35-162-03**  
 Issued by Water Resources Parcel No.

N/S R **53E E Nye** County  
**Cal-Vegas Ranchos** Subdivision Name

3. **WORK PERFORMED**

New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. **PROPOSED USE**

Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. **WELL TYPE**

Cable  Rotary  RVC  
 Air  Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
<b>brown loam</b>		<b>0</b>	<b>44</b>	<b>44</b>
<b>See next line</b>	<b>x</b>	<b>44</b>	<b>140</b>	<b>96</b>
<b>brown loam with caleche strings</b>				

8. **WELL CONSTRUCTION**

Depth Drilled **140** Feet Depth Cased **140+1** Feet  
**HOLE DIAMETER (BIT SIZE)**  
 From To  
**11** Inches **0** Feet **140** Feet  
 Inches Feet Feet  
 Inches Feet Feet

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>140</b>

**Perforations:**

Type perforation **sawcut**  
 Size perforation **.188**  
 From **120** feet to **140** feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** Neat Cement  
 Placement Method:  Pumped Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet

9. **WATER LEVEL**

Static water level **65** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cool** °F Quality **good**

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.**  
 Contractor

Address **2301 Winery Road, Suite 2**  
 Contractor

**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor

Date **2-26-01**



Date started **1/18/01** \_\_\_\_\_ 19\_\_\_\_  
 Date completed **1/18/01** \_\_\_\_\_ 19\_\_\_\_

7. **WELL TEST DATA**

TEST METHOD: Bailer Pump Air Lift  
 Draw Down (Feet Below Static) Time (Hours)  
 G.P.M.

