WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82642
Permit No.
Basin 162

NOTICE OF INTENT NO. 20793

1. OWNER Roach/Johnson
MAILING ADDRESS 1400 S. Linda
Pahrump, NV 89061

ADDRESS AT WELL LOCATION
1400 S. Linda

2. LOCATION SE 1/4 NE 1/4 Sec. 20 T 20S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
36-424-03 Parcel No.
SunLand Development Subdivision Name

3. WORK PERFORMED
X New Well, Deepen, Replace, Abandon, Recondition, Other

4. PROPOSED USE
X Domestic, Municipal/Industrial, Irrigation, Monitor, Test, Stock

5. WELL TYPE
Cable, Air, X Rotary, Other, RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	5	5
grey loam		5	27	22
See next line		27	60	33
grey clay with caleche strings				
See next line	x	60	76	16
light green loam with caleche strings				
See next line	x	76	160	84
brown loam with caleche strings				

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 161 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11	Inches	0 Feet	160 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X Yes No
Depth of Seal 50
Placement Method: Pumped, X Poured
Seal Type: Neat Cement, Cement Grout, X Concrete Grout

Gravel Packed: X Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date 2-26-01

DCNR/DWR Received MAY 2 2001 LAS VEGAS OFFICE

Date started 2/8/01 , 19__
Date completed 2/8/01 , 19__

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)