


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. **82645**  
 Permit No. **162**  
 Basin **162**



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20804

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER **Donald Dial**  
 MAILING ADDRESS **1950 E. Pioche**  
**Pahrump, NV 89048**

ADDRESS AT WELL LOCATION  
**1950 E. Pioche**

2. LOCATION **NW 1/4 NE 1/4 Sec. 2 T 21S**  
 PERMIT NO. **44-171-17**  
 Issued by Water Resources Parcel No.

N/S **R 53E E Nye** County  
**Gamebird** Subdivision Name

3. WORK PERFORMED

New Well  
 Deepen  
 Replace  
 Abandon  
 Recondition  
 Other

4. PROPOSED USE

Domestic  
 Municipal/Industrial  
 Irrigation  
 Monitor

5. WELL TYPE

Test  
 Stock  
 Cable  
 Air  
 Rotary  
 Other  
 RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	3	3
grey clay		3	8	5
brown caleche		8	17	9
See next line		17	23	6
brown loam with caleche strings				
brown caleche		23	25	2
brown loam	x	25	76	51
See next line	x	76	90	14
brown loam with caleche strings				
brown caleche	x	90	94	4
See next line	x	94	123	29
brown loam with caleche strings				
brown caleche	x	123	160	37

8. WELL CONSTRUCTION

Depth Drilled **160** Feet  
 Depth Cased **160+1** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
Inches	0	160	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:

Type perforation **sawcut**  
 Size perforation **.188**

From	to	feet
140	160	feet
From		feet

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  
 Poured

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **160** feet

9. WATER LEVEL

Static water level **55** feet below land surface  
 Artesian flow  G.P.M.  P.S.I.  
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.**  
 Contractor  
 Address **2301 Winery Road, Suite 2**  
 Contractor

**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Lacey Amick*  
 By driller performing actual drilling on-site or contractor  
 Date **4-28-01**



Date started **4/10/01** 19\_\_  
 Date completed **4/10/01** 19\_\_

7. WELL TEST DATA

TEST METHOD:  G.P.M.  
 Bailer Draw Down (Feet Below Static)  
 Pump Time (Hours)  
 Air Lift

