

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **82649**
 Permit No. **162**
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO: **20805**

1. OWNER **Barbara Thompson**
 MAILING ADDRESS **3171 W. Rand Lane**
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3171 W. Rand Lane

2. LOCATION **NE 1/4 NE 1/4 Sec. 1 T 20S**
 PERMIT NO. **28-432-07**
 Issued by Water Resources Parcel No.

N/S R 52E E Nye County
Vegas Acres Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial

4. PROPOSED USE
 Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	8	8
See next line		8	44	36
brown clay with caleche strings				
light grey caleche		44	49	5
See next line		49	62	13
grey clay with caleche strings				
brown clay	x	62	123	61
brown caleche	x	123	127	4
See next line	x	127	140	13
brown clay with caleche strings				

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
0		140		
11				

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From	feet to	feet
120	140	

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet



9. WATER LEVEL
 Static water level **62** feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **4/3/01** 19__
 Date completed **4/3/01** 19__

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on site or contractor
 Date **4-28-01**

