

OFFICE USE ONLY  
 Log No. 82729  
 Permit No. 102  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44539

1. OWNER Robert Skinkle ADDRESS AT WELL LOCATION 1960 E. 5th St. Silver Springs, Nevada  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec 2 T. 17 N/S R. 25 E. Lyon County  
 PERMIT NO. 117-153-09 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other rod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	60	
Clay		60	97	
Sand		97	131	
Clay		131	145	
Gravel		145	160	

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.00</u>	<u>3.16</u>	<u>11</u>	<u>20</u>
<u>6 5/8</u>	<u>3.00</u>	<u>Soft 40</u>	<u>20</u>	<u>160</u>

Perforations:  
 Type perforation Reill Saw  
 Size perforation 1 1/4 x 6 long 5 Rows  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 0-50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8-25  
 Date completed 8-26

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Produced about 30 GPM</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Teach Drilling Inc Contractor  
 Address PO Box 579 Silver Springs NV. 89927 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877  
 Signed \_\_\_\_\_ By driller performing actual drilling on site or contractor  
 Date 8-27-00

RECEIVED  
 00 NOV - 7 AM 11:43  
 STATE ENGINEERS OFFICE