

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 82750
 Permit No. 103
 Basin 103
 NOTICE OF INTENT NO. 45838

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER TOM WHITE ADDRESS AT WELL LOCATION 225 HIKO LANE
 MAILING ADDRESS 14505 MT. EMERSON DR. DAYTON, NV 89447
RENO, NV 89506
 2. LOCATION SW 1/4 SW 1/4 Sec 10 T 16 N R 22 E DOUGLAS County
 PERMIT NO. 16/371/07
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
COBBLES		0	3	3
CEMENTED GRAVELS		3	6	3
LOOSE COBBLES		6	15	9
VOLCANIC SANDS AND GRAVELS		15	67	52
BROWN CLAY		67	103	36
VOLCANIC SANDS		103	164	63
HARD BLACK SLATE		164	205	41
FACTURED VOLCANIC GRAVELS		205	220	25
HARD FRACTURED VOLCANIC GRAVELS		220	250	30

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 175 Feet
9 7/8 Inches 175 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation MILL SLOT
 Size perforation 3 X 3/32
 From 230 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. 22-23 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)

Date started 1/29, 20 01
 Date completed 2/1, 20 01

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>22-23</u>	<u>50</u>		<u>3 HRS</u>

Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Z Hack
 By driller performing actual drilling on site or contractor
 Date 2/5/01

RECEIVED
 01 FEB 23 AM 8:04
 STATE ENGINEERS OFFICE