WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82755 + 82756
Permit No.
Basin 61 T

NOTICE OF INTENT NO. 38340

1. OWNER Barrick Goldstrike Mines PZ01-1
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 36N N/S R 50E E Eureka County
PERMIT NO. ~~65141~~ (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray oxide vinnini		0	570	570
Black vinnini		570	650	80
Construction Detail:				
8" protective casing		+2	10	
Cement		0	59	59
Hole plug		59	375	316
Gravel pack		375	424	49
Hole plug		424	594	170
Gravel pack		594	650	56

RECEIVED 01 FEB 14 AM 11:49 STATE ENGINEER'S OFFICE

Date started 2/6/2001 , 19__
Date completed 2/10/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 638 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	25	Feet
7.875	Inches	25	Feet	650	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.75	0.500	0	25
1: 2.383	5.02	Sch. 80	+2	638
2: 2.383	5.02	Sch. 80	+2	418

Perforations:
Type perforation Milled Slot
Size perforation 0.125"
From 1: 598 feet to 638 feet
From 2: 378 feet to 418 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 59'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From See detail feet to feet

9. WATER LEVEL
Static water level 1: 547.9 2: Dry feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
Signed Dennis Robbins (By driller performing actual drilling on-site or contractor)
Date 2/12/01

USE ADDITIONAL SHEETS IF NECESSARY

B.St.C