WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82760
Permit No.
Basin

NOTICE OF INTENT NO. 44430

1. OWNER John Glatthar
MAILING ADDRESS 3759 Lyla Lane
Carson City, NV 89705-8401

ADDRESS AT WELL LOCATION Red Corral Trail

2. LOCATION NE 1/4 SE 1/4 Sec. 8 T 21N N/S R 22E E Washoe County
PERMIT NO. WaCo#6656 (Issued by Water Resources) 077-410-17 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & cobbles		0	20	20
White/Blue clay		20	260	240
Granite w/ some fractures		260	340	80
Fractured Granite	x	340	400	60

Date started 9/1/2000 , 19__
Date completed 9/8/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-15		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	50	Feet
10 5/8	Inches	50	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	400

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 160 feet to 180 feet
From 340 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/8/00

USE ADDITIONAL SHEETS IF NECESSARY