

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40017

1. OWNER Janet Beckett ADDRESS AT WELL LOCATION Intersection
 MAILING ADDRESS P.O. Box 907 2787 N. 21 West Street
 Searchlight, Nevada 89046

2. LOCATION NW 1/4 SE 1/4 Sec. 15 T. 17 N&R. 63 E. White Pine County
 PERMIT NO. Issued by Water Resources APN 005-581-61 Parcel No. Cross Timbers Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Sand & Course Gravel		5	30	25
Clay & Small Gravel		30	40	10
Brown Clay		40	70	30
Clay & Water Bearing Gravel	X	70	80	10
Brown Clay		80	100	20
Clay & Water Bearing Gravel	X	100	110	10
Brown Clay & Small Gravel		110	140	30
Water Bearing Sand & Gravel	X	140	155	15
Brown Clay		155	163	8

8. WELL CONSTRUCTION
 Depth Drilled 163 Feet Depth Cased 163 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 163 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	163

Perforations: Factory
 Type perforation
 Size perforation 1/8" x 2 1/2" 6 Rows
 From 102 feet to 163 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 163 feet

9. WATER LEVEL
 Static water level 73 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

Date started October 10, 2000
 Date completed October 13, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	85	77	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
 Ely, Nevada 89301
 Nevada contractor's license number 14790 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1793
 Signed Rich Lavinia By Marshall D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 17, 2000

RECEIVED
 00 OCT 19 PM 1:03
 STATE ENGINEER'S OFFICE