

OFFICE USE ONLY
 Log No. 82067
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42360

1. OWNER Roy Roach ADDRESS AT WELL LOCATION 360 Canyon Creek Rd
 MAILING ADDRESS 360 Canyon Creek Ct. Gardnerville, NV 89410 Gardnerville, NV 89410
 2. LOCATION SE 1/4 SE 1/4 Sec. 15 T 12 N 19 E Douglas County
 PERMIT NO. 19-420-130 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>D.G. Granite Boulders</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Compacted D.G. and Granite Boulders</u>	<u>X</u>	<u>140</u>	<u>240</u>	<u>100</u>

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 100 Feet To 240 Feet
 From 1 3/8 Inches 0 Feet To 100 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>+2</u>	<u>160</u>
<u>8 5/8</u>		<u>.188</u>	<u>180</u>	<u>230</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32
 From 160 feet to 180 feet
 From 220 feet to 240 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality _____

Date started 1-29-01, 19____
 Date completed 2-02-01, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20 to 30</u>	<u>Total</u>	<u>5 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump Service Contractor
 Address PO Box 2227 Dayton, NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Monty Lopez
 By driller performing actual drilling on site or contractor
 Date 2-10-01

RECEIVED
 FEBRUARY 14 11:15
 STATE ENGINEERS OFFICE