


OFFICE USE ONLY
 Log No. 82778
 Permit No. _____
 Basin. 107


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45901

1. OWNER Frank Ely ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 17823 Valley Blvd 38 Linda Wy
City of Industry, CA 91744 Wellington, NV 89444
 2. LOCATION NE 1/4 NE 1/4 Sec 26 T 12 N 33 E County _____
 PERMIT NO. 10 111 38 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	30	20
Grey Clay		30	60	30
Grey Sand Clay		60	100	50
Brown Sand Gravel	✓	110	130	20
Grey Sand & Clay		130	166	36

PREPARED BY: DATE: 0 MAY - 6 AM 11:38
 TITLE: NUMBER OF SHEETS: 1 OF 1

8. WELL CONSTRUCTION
 Depth Drilled 166 Feet Depth Cased 166 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 5/8 Inches To 166 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>sch 40</u>	<u>12</u>	<u>110</u>
<u>6 5/8</u>		<u>.188</u>	<u>+2</u>	<u>12</u>
<u>6</u>		<u>sch 40</u>	<u>130</u>	<u>166</u>

Perforations:
 Type perforation Factory
 Size perforation 0.321
 From 110 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 5.5
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 166 feet

9. WATER LEVEL
 Static water level 5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality NA

Date started 4-27
 Date completed 4-28

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AirLift</u>	<u>30-50</u>	<u>100</u>	<u>2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump & Drilling Contractor
 Address PO Box 2227 Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Monty Cooper
 By driller performing actual drilling on site or contractor
 Date 4-30-01