

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 82779
 Permit No. 1051
 Basin 1051
 NOTICE OF INTENT NO. 45860

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **JOHN WAHL CONSTRUCTION** ADDRESS AT WELL LOCATION **1919 SHEEP CAMP**
 MAILING ADDRESS **881 MAHOGANY DRIVE** **GARDNERVILLE, NV 89410**
MINDEN, NV 89423

2. LOCATION SE 1/4 SE 1/4 Sec 1 T 12 N R 20 E **DOUGLAS** County
 PERMIT NO. **1220-01-002-02**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
BROWN CLAY AND GRAVELS		3	28	25
COBBLES & GRAVELS		28	143	115
FRACTURED COBBLES WITH CLAY STRATAS		143	180	37
BROWN CLAY		180	190	10
FRACTURED COBBLES	XXX	190	240	50

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	240

Perforations:
 Type perforation **MILL SLOT**
 Size perforation **3 X 3/32**
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature **COLD** °F Quality **GOOD**

Date started 4/23, 20 01
 Date completed 4/25, 20 01

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>25</u>			
Draw Down (Feet Below Static)			
<u>45</u>			
Time (Hours)			
<u>3 HRS</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **41775**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**
 Signed Michael Black
 By driller performing actual drilling on site or contractor
 Date 4/27/01