

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45036

1. OWNER BILL & KAREN HANNEMAN ADDRESS AT WELL LOCATION 7215 Matterhorn Blvd.
MAILING ADDRESS 4921 Sun Valley Blvd. 7215 Matterhorn Blvd.
Sun Valley, Nevada 89433 Reno, Nevada 89506
2. LOCATION NW 1/4 N23 1/4 Sec 35 T 22N N/S R19 E Washoe County
PERMIT NO. 079-440-2169 Antelope Valley (Re) Rock Est. #274
Issued by Water Resources Parcel No. Subdivision Name 905-2

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown blow sand		1	3	2
Brown sandy clay		3	11	8
Brown sand		11	13	2
Brown sandy clay		13	37	24
Decomposed granite		37	47	10
Weathered granite		47	65	18
Clay streak		65	66	1
Weathered granite		66	81	15
Soft zone, rusty decomposed granite		81	87	6
Weathered granite		87	132	45
Soft zone (clay streak)		132	155	23
Weathered granite with clay streaks		155	168	18
Hard weathered granite		168	215	47
Soft zone (app 2 GPM)	X	215	217	2
Weathered granite		217	253	36
Fractured granite	X	253	259	6
Weathered granite		259	265	6
Fracture granite	X	265	283	18
Weathered granite		283	297	14
Weathered granite with quartz		297	300	3

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 300 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 235 feet to 295 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 feet Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 166 feet below land surface
Artesian flow _____ G.P.M. 25+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the 923 Division of Water Resources, the on-site driller.
Signed [Signature] By driller performing actual drilling on site or contractor
Date October 9, 2000

Date started October 2, 2000, 19____
Date completed October 5, 2000, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		