

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31434

1. OWNER CITY OF CARSON CITY ADDRESS AT WELL LOCATION EVERGREEN GOING NORTH  
 MAILING ADDRESS 3303 BUTTE WAY BLDG 1  
CARSON CITY, NV. 89901  
 2. LOCATION 1 1/4 SW 1/4 Sec. 5 T 15 N/S R. 20 E CARSON CITY County  
 PERMIT NO. DEW 023 well # 9  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic DOMESTIC  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AJCEL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY SAND		0	7	
CEMENTED SAND	9	7	9	
CLAY		9	11	
CEMENTED SAND		11	13	
CLAY		13	18	
CEMENTED SAND		18	21	
CLAY		21	25	

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 25  
24 Inches 0 Feet 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	.375	0	25

Perforations:  
 Type perforation SLOT  
 Size perforation .030"  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal N/A  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 10 feet to 25 feet

9. WATER LEVEL  
 Static water level 9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name VIKING DRILLERS INC. Contractor  
 Address 801 NORTAFORT DRIVE Contractor  
WEST SACRAMENTO, CA. 95691  
 Nevada contractor's license number 00044407  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the M-2091  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-9-00

Date started MARCH 9 2000  
 Date completed MARCH 9 2000

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	