

OFFICE USE ONLY
 Log No. 82819
 Permit No. 104
 Basin. 104
 31434

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31434

1. OWNER CITY OF CARSON CITY ADDRESS AT WELL LOCATION EVERGREEN GOING NORTH
 MAILING ADDRESS 13303 BUTTE WAY BLDG 1 CARSON CITY, NV. 89701 Well # E
 2. LOCATION 1/4 SW 1/4 Sec 5 T 15 N/S R 20 E CARSON CITY County
 PERMIT NO. DEW 023 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic DEWATER Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AJCEL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY SAND		0	7	
CEMENTED SAND	9	7	9	
CLAY		9	11	
CEMENTED SAND		11	13	
CLAY		13	18	
CEMENTED SAND		18	21	
CLAY		21	25	

CEMENTED SAND 12 TO 25

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 25 Feet
24 Inches 0 Feet 25 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	.375	0	25

Perforations:
 Type perforation SLOT
 Size perforation .030"
 From 5 feet to 25 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal N/A
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 10 feet to 25 feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started MARCH 9 2000
 Date completed MARCH 9 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VIKING DRILLERS INC. Contractor
 Address 801 NORTAFORT DRIVE Contractor
WEST SACRAMENTO, CA. 95691
 Nevada contractor's license number issued by the State Contractor's Board 00044407
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M-2091
 Signed S.P.R.
 By driller performing actual drilling on site or contractor
 Date 10-9-00