WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82901
Permit No.
Basin 162

NOTICE OF INTENT NO. 20700

1. OWNER Virginia Headley
MAILING ADDRESS Wilson Road Pahrump.
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NE ¼ Sec. 13 T. 20S N/S R 52 E E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 041-413-17 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light brown Clay		0	4	4
Grey Clay		4	26	22
Caliche		26	28	2
Grey Clay		28	40	12
Light brown Clay		40	55	15
Grey Clay	X	55	70	15
Light Green Clay	X	70	106	36
Caliche	X	106	109	3
Grey Clay	X	109	140	31

DCNR/DWR Received APR 3 2001 LAS VEGAS OFFICE

Date started 3-23-01, 19
Date completed 3-26-01, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	1/2

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC	Sch. 40	0	140

Perforations:
Type perforation Saw
Size perforation 1/8 X 6
From ____ feet to ____ feet
From 120 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry's Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-27-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627