

OFFICE USE ONLY  
Log No. 82937  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20388

1. OWNER Contri Const. ADDRESS AT WELL LOCATION On Olive St. West of Mezer  
MAILING ADDRESS L.V. NV

2. LOCATION N & NE 1/4 Sec. 6 T. 21 N. R. 62 E. Clark County  
PERMIT NO. DW 1116 161-06-50-001 thru 0-12  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Dewatering  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  PVC  
 Air  Other Driller

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>18 wells in these parcel areas</u>				
<u>fill</u>		<u>0</u>	<u>3</u>	
<u>Sandy clay</u>		<u>3</u>	<u>13</u>	
<u>Clay w/ silt</u>		<u>13</u>	<u>23</u>	
<u>Sandy clays w/ some gravel trace</u>		<u>23</u>	<u>35</u>	

8. WELL CONSTRUCTION  
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)  
From 24 Inches 0 Feet 35 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>35</u>

Perforations:  
Type perforation slot  
Size perforation .030  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 5 feet to 35 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
Depth of Seal \_\_\_\_\_  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 0 feet to 35 feet

9. WATER LEVEL  
Static water level 8 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-7-01 19\_\_\_\_  
Date completed 3-14-01 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Griffin Dewatering Contractor  
Address 536 E. Maitland Contractor  
Ontario CA  
Nevada contractor's license number issued by the State Contractor's Board 31246  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968  
Signed Griffin Dewatering  
By driller performing actual drilling on site or contractor  
Date 3-14-01

