

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83031
 Permit No. _____
 Basin 61

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38341

1. OWNER Barrick Goldstrike Mines PZ01-2 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION NW 1/4 SE 1/4 Sec. 19 T 36N N/S R 50E E Eureka County
 PERMIT NO. N/A Parcel No. N/A Subdivision Name N/A
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray & black with brown clay		0	120	120
Brown & white clay		120	130	10
Black rock		130	150	20
White clay		150	160	10
Brown, gray & black rock		160	270	110
White rock		270	300	30
Brown rock & clay		300	350	50
Red clay & rock		350	360	10
Light brown clay		360	370	10
Black rock		370	380	10
Red rock & clay		380	390	10
Black, brown, red & gray rock		390	440	50
Red clay & rock		440	450	10
Black, red & white rock		450	490	40
Brown clay with black & gray rock		490	530	40
Gray & red rock		530	640	110
Gray & black rock		640	710	70
Black rock		710	800	90

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 719 Feet
 HOLE DIAMETER (BIT SIZE)

From	To
19 Inches	0 Feet 70 Feet
7.875 Inches	70 Feet 740 Feet
6.375 Inches	740 Feet 800 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.75	0.500	0	70
1: 2.383	5.02	Sch. 80	+1	719
2: 2.383	5.02	Sch. 80	+1	479

Perforations:
 Type perforation Slot
 Size perforation 0.125"
 From 1: 679 feet to 719 feet
 From 2: 479 feet to 479 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From See Detail feet to _____ feet

Construction Detail:

Material	From	To	Thick-ness
Cement	0	50	50
Hole plug	50	405	355
Cement	405	425	20
Hole plug	425	435	10
Gravel pack	435	485	50
Hole plug	485	651	166
Cement	651	664	13

Continued on next page

Date started 2/11/2001, 19____
 Date completed 2/22/2001, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 1: No reading 2: 467.45 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2142
 Signed Alan Beaudoin
 By driller performing actual drilling on-site or contractor
 Date 3/13/01

B.S.T.L

