

OFFICE USE ONLY
Log No. 83094
Permit No. _____
Basin _____
NOTICE OF INTENT No. 39661

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Hendel ASS 230 Finchway ADDRESS AT WELL LOCATION Minden, TEXAS
MAILING ADDRESS MASON City, WY 1597 Hwy 395 Minden, WY

2. LOCATION NE 1/4 SW 1/4 Sec. 32 T. 13 N. R. 20 E. Douglas County
PERMIT NO. D/O m/o 1096 APP-025-211-01 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Aspe 2

6. LITHOLOGIC LOG MT 17 (19)

Material	Water Strata	From	To	Thick-ness
Well was too good				
Condition after				
Well cover was				
Taken off then				
I over drilled casing				
to the cement				
grout from bottom				
to surface				

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 0 Feet 30 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>FACTORY</u>	<u>0.20</u>	<u>0</u>	<u>30</u>

Perforations:
Type perforation Factory
Size perforation 6.20
From 4 feet to 30 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 30 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 30 feet to 30 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

Date started 2/16/01, 19____
Date completed 2/16/01, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling Contractor
Address 1635 Belford Rd Reno NV 89509 Contractor
Nevada contractor's license number 34525 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, on-site driller m-2139
Signed Kathy Bar By driller performing actual drilling on site or contractor
Date 2/16/01