

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **83046**  
 Permit No. **162**  
 Basin **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20807

1. OWNER **Ron Murphy**  
 MAILING ADDRESS **181 E. Irene**  
**Pahrump, NV 89041**

ADDRESS AT WELL LOCATION  
**181 E. Irene**

2. LOCATION **NW 1/4 NW 1/4 Sec. 10 T 20S**  
 PERMIT NO. **35-111-23**  
 Issued by Water Resources Parcel No.

N/S **R 53E** E **Nye** County  
 Nye Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other  Municipal/Industrial

4. PROPOSED USE  
 Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	16	16
brown caleche		16	23	7
See next line	x	23	113	90
brown loam with caleche strings				
brown caleche	x	113	123	10
See next line	x	123	151	28
brown loam with caleche strings				
brown caleche	x	151	157	6
See next line	x	157	160	3
brown loam with caleche strings				

8. WELL CONSTRUCTION

Depth Drilled **160** Feet Depth Cased **160+1** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
11 Inches	0	160	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:  
 Type perforation **sawcut**  
 Size perforation **.188**

From	feet to	feet
140	160	
From	feet to	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **160** feet



Date started **4/14/01** 19\_\_  
 Date completed **4/14/01** 19\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level **64** feet below land surface  
 Artesian flow  G.P.M.  P.S.I.  
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.**  
 Contractor  
 Address **2301 Winery Road, Suite 2**  
 Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **5-27-01**

