WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83061
Permit No.
Basin 212

NOTICE OF INTENT NO. 21377

1. OWNER Clark County Department of Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV 89111

ADDRESS AT WELL LOCATION 4813 South Paradise Road
Las Vegas, NV 89109

2. LOCATION SW ¼ SW ¼ Sec. 22 T. 21 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 162-22-401-002 (Parcel No.) AMN-4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay with gravel		0	10	10
Caliche		10	13	3
Clay with gravel		13	14	1
Caliche		14	18.5	4.5
Clay		18.5	20.5	2
Caliche		20.5	24	3.5
Silty sand		24	34.5	10.5
Clay		34.5	35	0.5

Date started 3/15/01, 19
Date completed 3/15/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches	0 Feet	35 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.218	0	30

Perforations:
Type perforation Factory slotted PVC
Size perforation 0.020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2', 2-4' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 35 feet

9. WATER LEVEL
Static water level 28.00 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number 48947 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources; the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

CONFIDENTIAL
Received
MAY 21 2001
Las Vegas Office

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627