

OFFICE USE ONLY  
 Log No. 83064  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21797

1. OWNER Robert M. Manning ADDRESS AT WELL LOCATION Vacant  
 MAILING ADDRESS \_\_\_\_\_  
6990 N. Jensen LV NV 89149  
 2. LOCATION SE 1/4 NW 1/4 Sec. 19 T 19S N/S R 60 E Clark County  
 PERMIT NO. 125-19-203-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	35	
Cemented Gravel		35	60	
Gravel		60	<del>888</del> 510	
Gravel & Water	xx	510	520	
Cemented Gravel		520	560	
Gravel & Water	xx	560	600	
Cemented Gravel		600	640	
Gravel & Water	xx	640	712	

8. WELL CONSTRUCTION  
 Depth Drilled 712 Feet Depth Cased 712 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches 0 Feet 55 Feet  
 To 7 7/8 Inches 55 Feet 712 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	55
5 1/2	PVC	SRD 21	+1	712

Perforations:  
 Type perforation Factory  
 Size perforation .030 Sieve Type  
 From 672 feet to 712 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet



Date started 5/14/01, 19\_\_\_\_  
 Date completed 5/23/01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 442 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 5360 Bonita Vista Contractor  
Las Vegas, NV. 89149  
 Nevada contractor's license number 10062 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller.  
 Signed V.H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 5-23-01

