

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19138**

1. OWNER Albert Villa ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3761 E. Navajo Blvd. Pahrump, NV \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 19 T. 21 N. DR. 54 E. Nye County \_\_\_\_\_  
 PERMIT NO. 45-272-08 Green Saddle Ranches Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	5'	5'
white clay		5'	20'	15'
caliche		20'	25'	5'
white clay		25'	30'	5'
brown clay		30'	70'	40'
caliche		70'	85'	15'
sandy clay		85'	105'	20'
caliche		105'	110'	5'
brown clay		110'	130'	20'
caliche		130'	135'	5'
brown clay		135'	140'	5'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.314	0	140

Perforations:  
 Type perforation saw cut  
 Size perforation 1 7/8" x 3"  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **PSI**  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.   
 Name Labrec Construction Co. Contractor  
 Address 4191 S. Jackie St. Pahrump, Nevada 89048 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0049225  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2114  
 Signed Forrest Labrec  
 By driller performing actual drilling on site or contractor  
 Date May 21, 2001

Date started May 16 2001  
 Date completed May 18 2001

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

