WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83071
Permit No.
Basin 162

NOTICE OF INTENT NO. 20219

1. OWNER Anthony Alsoi
MAILING ADDRESS P.O. Box 2411
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
900 N. Soy St
Pahrump, NV 89060

2. LOCATION NE ¼ NE ¼ Sec. 12 T. 20S N/S R. 52 E. Nye County
PERMIT NO. ~~27-542-11~~ (Issued by Water Resources) 27-542-11 (Parcel No.) None Lot 2 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Lite brown clay		4	28	24
Brown clay		28	42	14
Hard formation		42	46	4
Grey clay	x	46	96	50
Brown clay	x	96	140	44

DCNR/DWR Received MAY 29 2001 LAS VEGAS OFFICE

Date started May 16-2001, 19
Date completed May 17, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5/17/01	35	0	15 min

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	~~10~~ 0	140

Perforations:
Type perforation Torch cut
Size perforation ½" wide x 8" long
From feet to feet
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd (Contractor)
Pahrump, NV 89060
Nevada contractor's license number issued by the State Contractor's Board 7484A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by CLD (By driller performing actual drilling on site or contractor)
Date May 23, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627