

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42262

1. OWNER Michael G. Mason ADDRESS AT WELL LOCATION 773 Marron St
 MAILING ADDRESS PO Box 550 Gardnerville, NV 89410
Roseville, Ca 95678
 2. LOCATION N 1/2 1/4 NE 1/4 Sec. 20 T. 12 N. S. R. 20 E. Douglas County
 PERMIT NO. 122020001050 Ranchos

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt Cobbles</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Large Gravel Silt</u>		<u>10</u>	<u>30</u>	<u>20</u>
<u>Cobbles Silt</u>		<u>30</u>	<u>50</u>	<u>20</u>
<u>Cobbles Large Gravel and Silt</u>		<u>50</u>	<u>110</u>	<u>60</u>
<u>Gravel and Sand</u>		<u>110</u>	<u>160</u>	<u>50</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 Inches Feet Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>158</u>	<u>1</u>	<u>140</u>

 Perforations:
 Type perforation mill slot
 Size perforation 3/8 2
 From 140 feet to 160 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet
 9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality NA

RECEIVED
 MARCH 9 AM 11:35
 STATE ENGINEERS OFFICE

Date started 3-1-01 19__
 Date completed 3-2-01 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Airlift</u>	<u>50+</u>	<u>150</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump Service Contractor
 Address PO Box 2227 Contractor
Dayton, NV 89410
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Monty Lopez
 By driller performing actual drilling on site or contractor
 Date 3-5-01