WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83089
Permit No.
Basin 1051

NOTICE OF INTENT NO. 42253

1. OWNER John & Barbara Garcia
MAILING ADDRESS 766 Roan Cir GV NV 89410
ADDRESS AT WELL LOCATION 766 Roan Cir GV NV

2. LOCATION N ½ ¼ NE ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources
Parcel No. 1220245010 31
Subdivision Name Ruenstrouth

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels Cobbles and sand	✓	130	230	100

RECEIVED
01 MAR -9 AM 11:35
STATE ENGINEER'S OFFICE

Date started 3-7-01, 19
Date completed 3-7-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	20-25	210	2

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8	Inches	130 Feet	230 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		188	130	210

Perforations:
Type perforation Mill #6 Slot
Size perforation 3/32
From 210 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Deepen well
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump Service (Contractor)
Address 130 Prospector Rd Dayton NV 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Monty Tyler (By driller performing actual drilling on site or contractor)
Date 3-7-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627