WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83090
Permit No.
Basin 105

NOTICE OF INTENT NO. 42898

1. OWNER Indian Hills General Improvement Dist.
MAILING ADDRESS 924-D Mica Drive
Carson City, NV 89705

ADDRESS AT WELL LOCATION 3 miles south of Carson City, NV. on south side of Hwy 395 west

2. LOCATION NW 1/4 NW 1/4 Sec. 30 T 14N N/S R 20E E Douglas County
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
New Well | Replace | Recondition | X Abandon
Deepen | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | Rotary | RVC
Air | Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well was flowing approximately 15 gpm. We measured the depth of the well at 244'. We installed our sand bailer and bailed the well until we could not retreive any debris. We measured the well at a depth of 248.6'. We then installed our 8" Mills Knife and perforated 4 rows per foot from 210' back up to 63'. The following day, we installed 242' of 2" tremme pipe. We then pumped in approximately 6.5 yards of neat cement. I had the cement company mix the neat cement with 4.5 gallons of water per bag of cement to aid in holding the artesian pressure back. This well was not gravel packed and actually required twice the calculated volume of cement.				

Original logs attached

Date started 3/5/2010 , 19__
Date completed 3/6/2001 , 19__

7. WELL TEST DATA
TEST METHOD: Bailer | Pump | Air Lift
G.P.M. | Draw Down (Feet Below Static) | Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250' Feet Depth Cased 250' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	+3	250

Perforations:
Type perforation Mills Knife from 210' to 63'
Size perforation 210' to 250' mill slot .125 x 3
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes X No
Depth of Seal 250' to surface
Placement Method: X Pumped / Poured
Seal Type: X Neat Cement / Cement Grout / Concrete Grout

Gravel Packed: Yes X No
From feet to feet

9. WATER LEVEL
Static water level flowing feet below land surface
Artesian flow 15 gpm G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] By driller performing actual drilling on-site or contractor
Date 3/8/2001

USE ADDITIONAL SHEETS IF NECESSARY