


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83091  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44902



1. OWNER James Nicklos ADDRESS AT WELL LOCATION 1391 Hawkins Peak Court  
 MAILING ADDRESS P.O. Box 639 Gardnerville NV  
Fair Oaks, CA 95628

2. LOCATION SE 1/4 NE 1/4 Sec. 1 T 12N N/S R 20E E Douglas County  
 PERMIT NO. 23-483-250 Wildflower  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
air test 15 GPM				
sandy clay and gravel	no	0	65	65
brown sandy clay	no	65	103	38
sand and gravel	no	103	107	4
brown gummy clay	no	107	117	10
brown sandy clay	no	117	225	108
med. size well sorted gravel	no	225	233	8
brown gummy clay	no	233	235	2
unsorted med gravel	yes	235	277	42
dark grey clay and gravel	no	277	285	8
dark grey clay	no	285	293	8
course sand and pebbles	yes	293	312	19
dark grey clay	no	312	335	23

8. WELL CONSTRUCTION  
 Depth Drilled 335 Feet Depth Cased 335 Feet  
 HOLE DIAMETER (BIT SIZE)  

	From	To
10 5/8 Inches	0	60
9 7/8 Inches	60	285
6 1/8 Inches	285	335

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17	.188	+2	285
5 9/16	9	.188	275	335

Perforations:  
 Type perforation factory milled  
 Size perforation 1/8 X 3  
 From 240 feet to 280 feet  
 From 280 feet to 335 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 285 feet

9. WATER LEVEL  
 Static water level 265 feet below land surface  
 Artesian flow NA G.P.M. NA P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eddco Exploration Inc. Contractor  
 Address 7780 Curry Road Contractor  
Fallon, Nv. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 10/1/2000

Date started 9/14/2000, 19\_\_\_\_  
 Date completed 9/25/2000, 19\_\_\_\_

7. WELL TEST DATA

Air lift	TEST METHOD	Draw Down (Feet Below Static)		Time (Hours)
		<input type="checkbox"/> Bailor	<input type="checkbox"/> Pump	
	<input checked="" type="checkbox"/> Air Lift			<u>2hrs</u>

RECEIVED  
 OCT 10 PM 12:47  
 STATE ENGINEERS OFFICE  
 RECEIVED  
 OCT 10 PM 12:47  
 STATE ENGINEERS OFFICE