

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83131
 Permit No. 60051
 Basin 6.6

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45347

1. OWNER Newmont Mining Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 66 Box 69 _____
Golconda NV 89414-9801 _____
 2. LOCATION SE 1/4 NE 1/4 Sec. 30 T 39 N 43 E Humbolt County
 PERMIT NO. 60051 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Test
 Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
VD 103				
Alluvium	yes	0	300	300
Siltstone	yes	300	400	100
Waiver # 395				
Case hole to 400'				
Gravel pack from				
400' back to				
20' use 3/4				
hole plug to				
Keep cement				
out of Gravel				
cement from				
0 to 20'				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14 Inches 0 Feet 20 Feet
8 1/2 Inches 20 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>Sch 40</u>	<u>+2</u>	<u>400</u>

 Perforations:
 Type perforation slotted
 Size perforation .020
 From 20 feet to 400 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 20 feet to 400 feet

Date started 8-29-2000, 19____
 Date completed 9-6-2000, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow none G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Co
 Address P.O. Box 2748
Elko NV 89803
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1861
 Division of Water Resources, the on-site driller.
 Signed Paul Mikebon
 By driller performing actual drilling on site or contractor
 Date 9-25-00

RECEIVED
 SEP 28 AM 11:06
 THE ENGINEERS OFFICE