WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83185
Permit No.
Basin 92B

NOTICE OF INTENT NO. 44498

1. OWNER Rick Evans
MAILING ADDRESS 1237 Colusa Dr.
Reno, NV 89503

ADDRESS AT WELL LOCATION 655 Hungry Valley Rd.

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T 21N N/S R 19E E Washoe County
PERMIT NO. WaCo#6859 (Issued by Water Resources) 080-710-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Green/grey sandstone	x	172	235	63
Grey clay		235	239	4
Green/grey sandstone		239	245	6
Grey Fractured Granite	x	245	282	37

RECEIVED 01 APR 30 PM 2:00 STATE ENGINEER'S OFFICE

Date started 4/26/2001, 19__
Date completed 4/27/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 282 Feet Depth Cased 282 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	172	Feet	182	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	162	282

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 262 feet to 282 feet
From 202 feet to 222 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site of contractor
Date 4/27/01

USE ADDITIONAL SHEETS IF NECESSARY