

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Chris Hureta ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 505 Copper St  
Elko NV

2. LOCATION S.W. 1/4, R. 2, 1/4 Sec. 7 T. 34 N. S. R. 51 E. Eureka County \_\_\_\_\_  
 PERMIT NO. 00-38109 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To  | Thick-ness |
|------------|--------------|------|-----|------------|
| TOP soil   |              | 0    | 2   | 2          |
| cobble     |              | 2    | 8   | 6          |
| Clay sand  |              | 8    | 72  | 64         |
| granite    |              | 72   | 200 | 128        |
| sand clay  |              | 200  | 232 | 32         |
| granite    |              | 232  | 271 | 39         |
| Clay sand  |              | 271  | 380 | 109        |
| granite    |              | 380  | 420 | 40         |
| Sandstone  | X            | 420  | 453 | 23         |
| water sand | X            | 453  | 470 | 23         |
| Clay       |              | 470  | 480 | 10         |

8. WELL CONSTRUCTION  
 Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet 480 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6</u>           |                     | <u>188</u>              | <u>0</u>    | <u>480</u> |

Perforations:  
 Type perforation For  
 Size perforation \_\_\_\_\_  
 From 415 feet to 435 feet  
 From 450 feet to 470 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 480 feet

9. WATER LEVEL  
 Static water level 390 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name State Well Service Contractor  
 Address P.O. Box 10 Contractor  
Elko NV  
 Nevada contractor's license number issued by the State Contractor's Board 0038109  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Sha Bennett  
 By driller performing actual drilling on site or contractor  
 Date July - 10 - 97

Date started July 5 1997  
 Date completed July 10 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>20+</u> | <u>10</u>                     | <u>2</u>     |

RECEIVED  
 97 JUL 14 AM 11:45  
 STATE ENGINEER'S OFFICE