WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83241
Permit No. —
Basin 2/2

NOTICE OF INTENT NO. 21120

1. OWNER CLARK CO. SANITATION DISTRICT
MAILING ADDRESS 5857 EAST FLAMINGO RD.
LAS VEGAS, NV. 89112

ADDRESS AT WELL LOCATION 5857 E. FLAMINGO RD
LAS VEGAS NV 89112

2. LOCATION SW ¼ NE ¼ Sec. 22 T. 21 N/S R. 62 E. County
PERMIT NO. DW 1133 Issued by Water Resources
161-22-101-001 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEWATERING
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 28 WELLS | | | | |
| BROWN SANDY CLAY | | 0 | 17 | 17 |
| FINE SILTY SAND W/ BROWN SANDY CLAY LAYERS | | 17 | 38 | 21 |

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 36 Inches | 0 Feet | 38 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 33 | .250 | 0 | 5 |
| | | | | |

Perforations:
Type perforation LOUVERED
Size perforation .040
From 5 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 4
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout CLAY
Gravel Packed: ☑ Yes ☐ No
From 4 feet to 38 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING & CONST. CO. Contractor
Address 5175 CLAY AVE. Contractor
WYOMING, MI. 49548
Nevada contractor's license number issued by the State Contractor's Board 50826-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
Signed By driller performing actual drilling on site or contractor
Date 4-23-01

Date started 2-27-01, 19
Date completed 4-2-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 80 | 20 | 1 |

JUN 12 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-027