

OFFICE USE ONLY  
 Log No. 83272  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43848

1. OWNER CLARK CO. SANITATION DISTRICT ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5857 EAST FLAMMINGO RD. 5857 E. FLAMINGO RD.  
LAS VEGAS, NV. 89112 LAS VEGAS, NV. 89112  
 2. LOCATION NW 1/4 NW 1/4 Sec. 2322 T 21 N 62 E CLARK County  
 PERMIT NO. DW-1130 all 16122101001 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. P/W PROPOSED USE DEWATERING  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>63 WELLS</u>				
<u>BRN. SANDY CLAY</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>CALICHE W/ SAND &amp; GRAVEL LENSES</u>	<input checked="" type="checkbox"/>	<u>12</u>	<u>33</u>	<u>21</u>
<u>SOFT GRAY CLAY</u>		<u>33</u>	<u>38</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 38 Feet Depth Cased 37 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 20 Inches 0 Feet 38 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>33</u>	<u>.250</u>	<u>0</u>	<u>5</u>

Perforations:  
 Type perforation LOUVERED  
 Size perforation .040  
 From 5 feet to 37 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 4'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
CLAY  
 Gravel Packed:  Yes  No  
 From 4 feet to 38 feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name KELLEY DEWATERING & CONST. CO. Contractor  
 Address 5175 CLAY AVE. Contractor  
WYOMING, MICH. 49548  
 Nevada contractor's license number issued by the State Contractor's Board 50826-C23  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2149  
 Signed J. O. Eho  
 By driller performing actual drilling on site or contractor  
 Date 5-2-01

Date started 2-16-01, 19\_\_\_\_  
 Date completed 4-26-01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>100</u>	<u>23</u>	<u>1</u>

