WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 833
Permit No.
Basin 101

NOTICE OF INTENT NO. 44145

1. OWNER Gary Hutchings
MAILING ADDRESS 4650 Bottom Rd
Fallon, NV 89406

ADDRESS AT WELL LOCATION 585 Thornbrid Dr. Fallon
Nv. 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 6 T 18 N/S R 29 E Churchill County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Sand		10	13	3
Brown Clay		13	18	5
Brown Sand		18	30	12
Gray Sand		30	55	25
Black Clay		55	63	8
Gray Sand		63	87	24
Brown Clay		87	95	8
Brown Sand	xx	95	120	25

Date started 05/31/2000 , 19__
Date completed 05/31/2000 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 Hr

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 pvc	3.92	.258	20	120

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 115 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 06/01/2000

USE ADDITIONAL SHEETS IF NECESSARY