WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83338
Permit No.
Basin 102

NOTICE OF INTE[redacted]216

1. OWNER Jammie Casey
MAILING ADDRESS 1005 Ruby Ave
Silver Springs, NV 89409

ADDRESS AT WELL LOCATION 1005 Ruby Ave Silver Springs

2. LOCATION NW 1/4 NW 1/4 Sec. 15 T 18 N/S R 24 E Lyon County
PERMIT NO. _____ Issued by Water Resources
15-121-29-1c Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Sand and Gravel		10	67	57
Brown Clay and Gravel		67	180	113
Brown Clay		180	240	60
Brown Clay and Gravel		240	410	170
Black Volcanic rock		410	450	40

Date started 04/20/2000 , 19__
Date completed 04/24/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr

8. **WELL CONSTRUCTION**
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	450	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	450

Perforations:
Type perforation Mill cut
Size perforation 1/8
From 410 feet to 450 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 450 feet

9. **WATER LEVEL**
Static water level 360 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 05/30/2000

USE ADDITIONAL SHEETS IF NECESSARY