WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8334
Permit No.
Basin 89

NOTICE OF INTENT NO. 44437

OWNER Rich Riolo
MAILING ADDRESS 1490 Brenda Way
Carson City, NV 89704

ADDRESS AT WELL LOCATION 1490 Brenda Way

2. LOCATION SW 1/4 NW 1/4 Sec. 30 T 17N N/S R 20E E Washoe County

PERMIT NO. WaCo#6674 (Issued by Water Resources) | 050-278-06 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [x] Deepen
- [ ] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [ ] Rotary
- [ ] RVC
- [x] Air
- [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown decomposed granite		184	290	106
Black & White Granite	x	290	324	34

Date started 9/27/2000, 19__
Date completed 9/28/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [x] Pump [x] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumped	22	32	2 Hrs
Air Blown	40+		2 Hrs

8. WELL CONSTRUCTION

Depth Drilled 324 Feet Depth Cased 324 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		184 Feet	324 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	174	324

Perforations:
Type perforation Factory mill slot
Size perforation 3/32 x 3"

From 184 feet to 204 feet
From 304 feet to 324 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured

Seal Type:
- [ ] Neat Cement
- [ ] Cement Grout
- [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL

Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/29/00

USE ADDITIONAL SHEETS IF NECESSARY